

Pump Station - Single User ST915

Designed to Launceston City Council standards

1	FLYGT PUMP CF 3057
2	DISCHARGE / RISING MAIN - HDPE ELECTRO FUSION
3	NON RETRUN VALVE, FLYGT- HDL
4	ISOLATING VALVE
5	CONNECTION POINT
6	GRAVITY SEWER MAIN INLET
7	ACCES COVERS FOR PUMP
8	ALARM LEVEL REGULATOR
9	LIFTING CHAIN GALVANISED GRADE L
10	BENCHING / SLUDGE BATTER
11	EPOXY SEALED JOINT
12	PUMP CHAMBER SPECIFICATIONS
	CONCRETE - SULPHUR RESISTANT CEMENT
	50 MPA @ 28 DAYS
13	SWIFT LIFT' PINS FOR SAFE HANDLING

